Ð	PLOLABS (BP	LOLARS EPIOLAR	STICLES BELOURS BELOU	NS BPLOURS BPLOURS BPLOURS BY	PLOLARS (RPLOLARS		
BFIOLNE	7 Spanner Rd / PO Box 467 Olifantsfontein 1665						
		Explosion Preve	ention Services (Pty) Ltd		27 (11) 316 4601 27 (11) 316 5670		
	Rea No: 1999/027771/07 E-mail: admin-mgr@explolabs.co.za						
POWNS -	GOVERNMENT APPROVED TEST LABORATORY						
			IA CERTI				
EPIOLARS				Date Issued: *Expiry date:	21 Jan 2019 21 Jan 2022 Page 1 of 3 Issue: 0		
SINOINS	Ex – Type Examination Certificate Certificate Number: S-XPL/19.0036 X Equipment: Multi-touch Panel PC and Multi-touch Control Panel						
	Model / Ty	pe:	Multi-touch Panel PC Se Series CPX39	eries CPX37 and Multi-touch Con	trol Panel		
SIMOLUR	Applicant: Beckhoff Automation (Pty) Ltd						
Sector Standpark Ridge							
XPIOI			Randburg, Gauteng 2169, South Africa		with Terror		
PIOUNS (Manufactu Serial No:	Manufacturer: Beckhoff Automation GmbH & Co. KG Serial No: All serial numbers imported between issued- and expire date and all serial					
	المعادية من عام عام المعاد المعاد المعاد المعاد						
SIVIC	Supplied by Beckhoff Automation (Pty) Ltd						
	Identified by Inspection Authority number						
	And as described in the Explolabs file number XPL/20209/19.0036 is hereby certified "Explosion Protected key (Refer to clause 1, for Ex Rating)", having been examined and inspected in accordance with the relevant						
8	requirements of South African Standards.						
	SANS 60079-0: 2012 Ed 5 Explosive atmospheres Part 0: Equipment — General requirements						
8	IEC 60079-0: 2011 Ed 6 SANS 60079-15: 2010 Ed 4 Explosive atmospheres Part 15: Equipment protection by type of IEC 60079-15: 2010 Ed 4 protection "n"						
	SANS 60079-31: 2014 Ed 2 Explosive atmospheres Part 31: Equipment dust ignition protection by enclosure "t"						
Risk of ignition provided:							
STUDINE.	Protection afforded	Equipment Protection Level (EPL) Group	Performance of protection	Conditions of operation	T class or Max Surface Temp (°C)		
EPHOLARS	Enhanced	Gc Group II		Equipment remains functioning in zone 2	T5 (100°C)		
	Enhanced	Dc Group III	Suitable for normal operation	Equipment remains functioning in zone 22	T100°C		
	This certification indicates compliance with R10.1 of the Mines Health and Safety Act and/or EMR 9(2) of the Occupational Health and Safety Act, provided						
	that the apparatus is used as relevant in appardance with:						
	ii) Any relevant requirements and codes of practice enforced in terms of the Mine Health and Safety Act or Occupational Health and Safety Act; 🗥						
	and Any restrictions and conditions enforced by the Chief Inspector of Mines or the Principal Inspector or the Chief Inspector: Occupational Health and Safety. A revision certificate replaces all previous version of the certificate.						
STIOLARS	 If and when your QAN (Quality Assurance Notification) Certificate for your equipment manufacturer expires during the valid period of the IA Certification (issued for your equipment) and a new certificate is not submitted the existing IA Certification will then be cancelled. It is thus the client's responsibility to always submit the updated and valid QAN certificate(s) to Explolabs (Pty) Ltd 						
DOCUMENT No: XPL0213 RELEASE DATE: 29/05/2018 REV : 7							
- 4	EXPLOIABS (EX	ABRIOLIUS					

NALON NO	ANNEX TO CERTIFICATE NO S-XPL/19.0036 X PAGE 2 OF 3
	GENERAL The marking of the Multi-touch Panel PC and Multi-touch Control Panel shall include the following: Ex nA IIC T5 Gc and Ex tc IIIC T100 °C Dc
s Astriouxs Astrioux	Multi-touch Panel PC Series CPX370010 and Multi-touch Control Panel Series CPX390010 are panel PC's designed for industrial application intended for mounting in a 100x100 mm mounting interface.
SIMOLIS	Depending on the model code and the options, the Multi-touch Panel PC and Multi-touch Control Panel has a display size of 15", 19" or 21".
STIOURS	Nomenclature: CPX37xx-0010 / CPX39xx-0010, xx indicates the display size and can be 15,19 or 21.
SIMUOINE	Electrical data Supply: 24 Vdc, max. 1.7 A.
@	Based on the following documentation: IECEx DEK 18.0028X Issue No.: 0
2. ¥	INSTALLATION INSTRUCTIONS It is the manufacturer's responsibility to supply installation instructions with each unit offered for sale as required by IEC/SANS 60079-0 Clause 30.
3.	SPECIAL CONDITIONS FOR SAFE USE (denoted by "X" after certificate number) For type of protection Ex nA and Ex t: Ambient temperature range: 0 °C to 45 °C for Series CPX37 0 °C to 50 °C for Series CPX39
SIVIC	The equipment shall be installed in such a way that the risk of mechanical danger is low.
IOLARS HERIOLARS	For Ex nA: The equipment shall only be used in an area of not more than pollution degree 2, as defined in IEC 60664-1.
NA NA	Provisions shall be made to prevent the rated voltage from being exceeded by transient disturbances of more than 119 V.
4 .	SCHEDULE OF LIMITATIONS (denoted by "U" after certificate number) None.
5.	CONDITIONS OF CERTIFICATION All production units must be covered by a QAN (Quality Assurance Notification), Product Mark Scheme or batch evaluation.
STIOLAS	
SIMOL	
W	DOCUMENT No: XPL0213 RELEASE DATE: 29/05/2018 REV : 7

DOCUMENT No: XPL0213 RELEASE DATE: 29/05/2018 REV : 7

epiciaes (exploraes ANNEX TO CERTIFICATE NO S-XPL/19.0036 X PAGE 3 OF 3 6. MARKING The following (or similar) information have to be clearly and permanently marked on all units: : Beckhoff Automation (Pty) Ltd Supplier : Beckhoff Automation GmbH & Co. KG Manufacturer : Multi-touch Panel PC and Multi-touch Control Panel Equipment Model/Type : Multi-touch Panel PC Series CPX37.. and Multi-touch Control Panel Series CPX39.. Serial No. : ---Ex Rating : Ex nA IIC T5 Gc and Ex tc IIIC T100 °C Dc

This report/certificate shall not be reproduced except in full without the written approval of the company Explolabs (Pty) Ltd shall not be liable for any losses or damages sustained on account of any failure or omission to properly perform our duties in terms of any contract undertaken by us. This disclaimer is immutable and automatically incorporated in any contract undertaken by us; notwithstanding anything to the contrary, save for the express written waiver of our managing director. By marking the equipment in accordance with the documentation/standard, the relevant standards and that the routine verifications and tests have been successfully completed and that the product complies with the documents of electronic reports/certificates cannot be guaranteed. Original certification documents will be

IA Certificate No

W.

kept on file at Explolabs (Pty) Ltd

D Maree Testing Officer

Responsible Testing Officer:

: S-XPL/19.0036 X

EXPLOLABS EXPLOSION PREVENTION SERVICES