



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX EPS 21.0018X** Page 1 of 3 [Certificate history:](#)
Status: **Current** Issue No: 0
Date of Issue: 2021-07-08
Applicant: **Beckhoff Automation GmbH & Co. KG**
Hülshorstweg 20
Verl 33415
Germany
Equipment: **PS9401-2420-0000; PS9401-2440-0000; PS9421-4840-0000**
Optional accessory: N/A
Type of Protection: **ec**
Marking: Ex ec IIC T4 Gc

Approved for issue on behalf of the IECEx
Certification Body:

Position:

Signature:
(for printed version)

Date:

Holger Schaffer

Certification Manager

2021-07-08



1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Bureau Veritas Consumer Products Services Germany GmbH
Businesspark A96
86842 Türkheim
Germany





IECEX Certificate of Conformity

Certificate No.: **IECEX EPS 21.0018X**

Page 2 of 3

Date of issue: 2021-07-08

Issue No: 0

Manufacturer: **Beckhoff Automation GmbH & Co. KG**
Hülshorstweg 20
Verl 33415
Germany

Additional
manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-7:2017 Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

DE/EPS/ExTR21.0053/00

Quality Assessment Report:

DE/BVS/QAR16.0010/05



IECEX Certificate of Conformity

Certificate No.: **IECEX EPS 21.0018X**

Page 3 of 3

Date of issue: 2021-07-08

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

PS9401-2420-0000

Input 1+2:

1: DC 12-28V ($\pm 30\%$), 20A continuous, 32.5A up to 5s

2: DC 12-28V ($\pm 30\%$), 20A continuous, 32.5A up to 5s

Output:

40A continuous, 65A up to 5s (below 60°C)

30A continuous, 65A up to 5s (at 70°C)

Derate linearly between +60°C and +70°C

Input to output voltage loss: typ. 0.072V

PS9401-2440-0000

Input 1+2:

1: DC 12-28V ($\pm 30\%$), 20A continuous, 32.5A up to 5s

2: DC 12-28V ($\pm 30\%$), 20A continuous, 32.5A up to 5s

Output:

40A continuous, 65A up to 5s (below 70°C)

Input to output voltage loss: typ. 0.072V

PS9421-4840-0000

Input 1+2:

1: DC 12-28V ($\pm 30\%$), 20A continuous, 32.5A up to 5s

2: DC 12-28V ($\pm 30\%$), 20A continuous, 32.5A up to 5s

Output:

40A continuous, 65A up to 5s (below 60°C)

30A continuous, 65A up to 5s (at 70°C)

Derate linearly between +60°C and +70°C

Input to output voltage loss: typ. 0.072V

SPECIFIC CONDITIONS OF USE: YES as shown below:

- The equipment shall be installed in an enclosure that provides a degree of protection not less than IP 54 in accordance with IEC 60079-0.
- The equipment shall only be used in an area of not more than pollution degree 2, as defined in IEC 60664-1.
- Output power de-rating conditions at high ambient temperatures must be considered according to manufacturer's instructions.