

EC-Type Examination Certificate

No. M6A 062386 0093 Rev. 00

Holder of Certificate: **Beckhoff Automation GmbH & Co. KG**
Hülshorstweg 20
33415 Verl
GERMANY

Product: **Safety components**

Model(s): **EL6900**

Parameters: Supply voltage: 24VDC (-15%...+20%)
Power dissipation: 2W
Protection class: IP20

with "TwinSAFE Verifier" or "CODESYS Safety for EtherCAT Safety Module".

Note: "CODESYS Safety for EtherCAT Safety Module" is developed in accordance with IEC EN 61508:2010.

This EC Type Examination Certificate is issued according to Article 12(3) b or 12(4) a of Council Directive 2006/42/EC relating to machinery. It confirms that the listed Annex-IV equipment complies with the principal protection requirements of the directive. It refers only to the sample submitted to TÜV SÜD Product Service GmbH for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: BV100963C

Valid until: 2028-06-13

Date, 2023-06-16



(Peter Weiß)